


**MCS (MIS 3005) Important Changes;
what will need doing.... *(a very brief précis)***

David Matthews, Chief Executive
Ground Source Heat Pump Association

16th September 2011, Geological Society, London

EST trial results compared to Switzerland & Germany

GSHP



SFOE, 2010; Fraunhofer ISE, 2010, EST, 2010

Air Collector Systems:

- Noise
- Location (good air flow & connection)
- Defrost cycles
- Undersizing
- Oversizing
- Inaccurate heat loss calculation
- Poor heat distribution design or install
- Inadequate control strategy
- Commissioning, Handover & Maintenance

Ground Collector Systems:

- Undersizing
- Oversizing
- Inaccurate heat loss calculation
- Poor heat distribution design or install
- Inadequate control strategy
- Commissioning, Handover & Maintenance
- Inadequate collector design
- Inadequate collector install

Some Ground Collector Faults:

- Not enough surface area/depth or proximity
- Overlapping pipework
- Poor materials (pipes, antifreeze etc)
- Poor hydraulic design (massive pumps)
- Poor backfilling or grouting
- Poor drilling/trenching practice
- No capping off
- Poor purging and filling
- Inadequate joints

Heat Loss Calculation (HLC) complies BS EN 12831 software compliant BS EN 12831. *i.e. good HLC*

ROOM	KITCHEN/DINING	JOB	Dom Heat Des Guide			Amount	Air	Design	Heat Loss	Variation from DHDG
Design Room Temp	21	No of air				air heated	change	Temp		
Outside Design Temp	-1.8	changes				per hour	factor	Difference		Design temp was -3 C
Design Temp Diff	22.8	per hour	Length m	Width m	Height m	m3/hour	w/m3K	°C	Watts	
VENTILATION HEAT LOSS		2	4.9	2.7	2.4	63.50	0.33	22.8	478	
Fabric Heat Loss						Area m2	U-Value			
FLOOR			4.9	2.7		13.23	0.79	22.8	238	
EXT WALL (gross area)			7.6		2.4	18.24				
WINDOW GLAZING				1.1	1.05	1.16	4.8	22.8	126	Single Glazing
DOOR				1.75	2.1	3.68	4.8	22.8	402	Single Glazing
EXT WALL (net area)	Subtract glazing & door from gross ext wall area					13.41	0.68	22.8	208	
CEILING or ROOF (gross area)			2.33	1.92		4.47	Heat gain from bathroom			
ROOF GLAZING				0	0	0.00	0	0	0	
CEILING or ROOF (net area)	Subtract roof glazing from gross roof area					4.47	1.41	-1	-6	
INTERNAL WALL 1			0		0	0	0	0	0	
INTERNAL WALL 2			0		0	0	0	0	0	
PARTY WALL			2.7		2.4	6.48	1.02	11	73	
OTHER			0	0	0	0	0	0	0	
DESIGN HEAT LOSS FOR ROOM (Sum of Watts for all elements)									1519	
EXPOSED LOCATION	Yes If YES, add			10 % to DESIGN HEAT LOSS					152	
HIGH CEILING	No If YES, add			0 % to DESIGN HEAT LOSS					0	
INTERMITTENT HEATING	Add			0 % to DESIGN HEAT LOSS					0	No intermittent heating
TOTAL ROOM HEAT LOSS									1671	

Heat Loss Calculation (HLC) complies BS EN 12831 software compliant BS EN 12831. *i.e. good HLC*

ROOM	KITCHEN/DINING	JOB	Dom Heat Des Guide			Amount	Air	Design	Heat Loss	Change
Design Room Temp	21	No of air				air heated	change	Temp		
Outside Design Temp	-1.8	changes				per hour	factor	Difference		
Design Temp Diff	22.8	per hour	Length m	Width m	Height m	m3/hour	w/m3K	°C	Watts	
VENTILATION HEAT LOSS	1.5		4.9	2.7	2.4	47.63	0.33	22.8	358	Draft proof
Fabric Heat Loss						Area m2	U-Value			
FLOOR			4.9	2.7		13.23	0.37	22.8	112	50 mm U/F insulate
EXT WALL (gross area)			7.6		2.4	18.24				
WINDOW GLAZING				1.1	1.05	1.16	2.1	22.8	55	Low E glass door
DOOR				1.75	2.1	3.68	2.1	22.8	176	Low E glass door
EXT WALL (net area)	Subtract glazing & door from gross ext wall area					13.41	0.39	22.8	119	Cavity wall insulate
CEILING or ROOF (gross area)			2.33	1.92		4.47	Heat gain from bathroom			
ROOF GLAZING				0	0	0.00	0	0	0	
CEILING or ROOF (net area)	Subtract roof glazing from gross roof area					4.47	1.41	-1	-6	
INTERNAL WALL 1			0		0	0	0	0	0	
INTERNAL WALL 2			0		0	0	0	0	0	
PARTY WALL			2.7		2.4	6.48	1.02	11	73	
OTHER			0	0	0	0	0	0	0	
DESIGN HEAT LOSS FOR ROOM (Sum of Watts for all elements)									887	
EXPOSED LOCATION	Yes If YES, add					10 % to DESIGN HEAT LOSS			89	
HIGH CEILING	No If YES, add					0 % to DESIGN HEAT LOSS			0	
INTERMITTENT HEATING	Add					0 % to DESIGN HEAT LOSS			0	
TOTAL ROOM HEAT LOSS									976	

Internal and external temperatures recommended in CIBSE Guide A: Environmental Design

Room	Internal design temperatures (°C) from the UK national annex to BS EN 12831
Living room	21
Dining room	21
Bedsitting room	21
Bedroom	18
Hall and landing	18
Kitchen	18
Bathroom	22
Toilet	18

Floor Heat Loss - local annual average external air temperature.

Location	Altitude (/m)	Hourly dry-bulb temperature (°C) equal to or exceeded for 99% of the hours in a year
Belfast	68	-1.2
Birmingham	96	-3.4
Cardiff	67	-1.6
Edinburgh	35	-3.4
Glasgow	5	-3.9
London	25	-1.8
Manchester	75	-2.2
Plymouth	27	-1.2

In the absence of more localised info, data from the closest location decreased by 0.6 °C for every 100m height above sea level - may be used,

i.e. take account of local internal and external conditions

Heat Loss Calculation (HLC) complies BS EN 12831 software compliant BS EN 12831. *i.e. good HLC*

ROOM	KITCHEN/DINING	JOB	Dom Heat Des Guide			Amount	Air	Design	Heat Loss	Change
Design Room Temp	21	No of air				air heated	change	Temp		
Outside Design Temp	-1.8	changes				per hour	factor	Difference		
Design Temp Diff	22.8	per hour	Length m	Width m	Height m	m3/hour	w/m3K	°C	Watts	
VENTILATION HEAT LOSS	1.5		4.9	2.7	2.4	47.63	0.33	22.8	358	Draft proof
Fabric Heat Loss						Area m2	U-Value			
FLOOR			4.9	2.7		13.23	0.37	22.8	112	50 mm U/F insulate
EXT WALL (gross area)			7.6		2.4	18.24				
WINDOW GLAZING				1.1	1.05	1.16	2.1	22.8	55	Low E glass door
DOOR				1.75	2.1	3.68	2.1	22.8	176	Low E glass door
EXT WALL (net area)	Subtract glazing & door from gross ext wall area					13.41	0.39	22.8	119	Cavity wall insulate
CEILING or ROOF (gross area)			2.33	1.92		4.47	Heat gain from bathroom			
ROOF GLAZING				0	0	0.00	0	0	0	
CEILING or ROOF (net area)	Subtract roof glazing from gross roof area					4.47	1.41	-1	-6	
INTERNAL WALL 1			0		0	0	0	0	0	
INTERNAL WALL 2			0		0	0	0	0	0	
PARTY WALL			2.7		2.4	6.48	1.02	11	73	
OTHER			0	0	0	0	0	0	0	
DESIGN HEAT LOSS FOR ROOM (Sum of Watts for all elements)									887	
EXPOSED LOCATION	Yes If YES, add			10 % to DESIGN HEAT LOSS					89	
HIGH CEILING	No If YES, add			0 % to DESIGN HEAT LOSS					0	
INTERMITTENT HEATING	Add			0 % to DESIGN HEAT LOSS					0	
TOTAL ROOM HEAT LOSS									976	



Heat Loss Calculation (HLC) complies BS EN 12831 software compliant BS EN 12831. *i.e. good HLC*

ROOM	KITCHEN/DINING	JOB	Dom Heat	Des Guide	Amount	Air	Design	Heat Loss	Change
Design Room Temp	21	No of air			air heated	change	Temp		
Outside Design Temp	-1.8	changes			per hour	factor	Difference		
Design Temp Diff	22.8	per hour	Length m	Width m	Height m	m3/hour	w/m3K	°C	Watts
VENTILATION HEAT LOSS	1.5	4.9	2.7	2.4	47.63	0.33	22.8	358	Draft proof
Fabric Heat Loss					Area m2	U-Value			
FLOOR		4.9	2.7		13.23	0.23	11	33	screed U/F; 100mm
EXT WALL (gross area)		7.6		2.4	18.24				
WINDOW GLAZING			1.1	1.05	1.16	2.1	22.8	55	Low E glass door
DOOR			1.75	2.1	3.68	2.1	22.8	176	Low E glass door
EXT WALL (net area)	Subtract glazing & door from gross ext wall area				13.41	0.39	22.8	119	Cavity wall insulate
CEILING or ROOF (gross area)		2.33	1.92		4.47	Heat gain from bathroom			
ROOF GLAZING			0	0	0.00	0	0	0	
CEILING or ROOF (net area)	Subtract roof glazing from gross roof area				4.47	1.41	-1	-6	
INTERNAL WALL 1		0		0	0	0	0	0	
INTERNAL WALL 2		0		0	0	0	0	0	
PARTY WALL		2.7		2.4	6.48	1.02	11	73	
OTHER		0	0	0	0	0	0	0	
DESIGN HEAT LOSS FOR ROOM (Sum of Watts for all elements)									809
EXPOSED LOCATION	Yes	If YES, add		10 %	to DESIGN HEAT LOSS			81	
HIGH CEILING	No	If YES, add		0 %	to DESIGN HEAT LOSS			0	
INTERMITTENT HEATING	Add			0 %	to DESIGN HEAT LOSS			0	
TOTAL ROOM HEAT LOSS									890



provide at least **100%** of the calculated design **space heating**
power requirement at the selected internal and external temperatures, the
selection being made after taking into consideration the space heating **flow**
temperature assumed in the heat emitter circuit and any variation in
heat pump performance that may result.

Please note: *-100% includes defrost cycles and no immersion heater within space
heating design zone*

Impact of power coverage on SPF and electricity demand on coldest hour



Impact of power coverage on SPF and electricity demand on coldest hour



Bivalent fossil-fuel & HP heat sources must be fully integrated into single CH control circuits. CH = Space & HW

For bivalent fossil-fuel & HP heating circuits, the percentage fossil-fuel and HP contribution must be clearly stated in the quote

For DHW design purposes, use BS 6700 and take into account the number and type of points of use

There is a comment about HW cylinders needing larger HX with HPs

Legionella and other bacteria management with HP and HW circuits

e.g. pasteurised for 60 °C for 60 minutes every 24 hours

Domestic selection guide

These recommendations are based on the guidelines in BS 6700. Guidance should be sought for unusual applications. Eg: High flow-rate showers, large baths etc.

Hot Water Demand	Bedrooms	Indirect units	Direct units
1 Standard Bath or Shower	Bedsit / 1 Bed	60/90	150
	2 – 3 Bed	120	180
	3 – 4 Bed	150	210
1 Standard Bath	2 – 3 Bed	120	180
	3 – 4 Bed	150	210
1 Bath and En-suite	2 – 3 Bed	150	210
	3 – 4 Bed	150	210
	4 – 5 Bed	180	250
2 Standard Baths	2 – 3 Bed	180	210
	3 – 4 Bed	180	210
	4 – 5 Bed	210	250
3 Bathrooms	3 – 4 Bed	250	300
	4 – 5 Bed	250	300



Contractor shall communicate to the customer the running cost of the system under normal design conditions including:

- *Estimated annual HP electricity cost*
- *Electricity cost of CH & GL pumps, especially any 24/7 pumps*
- *HL associated with storage vessels (Part L cyl & pipework insulation)*
- *Electricity cost of any HW immersion heater usage*

Heat Emitter Guide *Customer aware and see*

- *Room Heat Loss*
- *Emitter type and emitter temperature (worst room)*
- *Temperature Star Rating and possible improvement*
- *Flow temperature*
- *SPF*



Heat Emitter Guide for Domestic Heat Pumps

Heat pumps can provide high-efficiency low-carbon heat for dwellings. Their performance is optimised if low-temperature heat emitters are used for heat distribution in the house, so this guide aims to help you select an emitter type and operating temperature which will result in high efficiency and low running costs.

The guide uses a Temperature Star Rating to indicate how efficient the proposed system is likely to be. More efficient systems are given a higher number of stars. The maximum is 6 stars. More stars are given when lower heat emitter temperatures are used because the heat pump is able to operate more efficiently.


The guide can be used for systems with existing radiators or to design a new heat emitter system. A flow chart has been designed to help you through the process for an individual room. This process should be repeated for all of the heated rooms in the dwelling, the heat pump operating SPF will be limited by the worst performing room.

The Guidance Table over the page is annotated to help you achieve the most suitable design for the room/dwelling. Several examples are also included in the guide to illustrate the advantages of improving the energy efficiency by reducing fabric and ventilation heat loss and achieving lower emitter temperatures.



The emitter guide is not a detailed design tool, but is intended to stimulate a proper review of the dwelling-specific heat load and heat emitter design, leading to optimised performance and low running costs.

Who produced this guide?

Trade Associations representing heat pumps and heat distribution technologies have worked together to produce this useful guide which is supported by DECC and ESI. Participating members are:



Use the chart and the calculated Oversize Factor to determine the Temperature Star Rating for that room:



EXAMPLES for EXISTING RADIATOR SYSTEMS

Calculating the Temperature Star Rating of an existing radiator system
 An example of a poorly-insulated room has been adapted from CIBSE's Domestic Heating Design Guide. The room is assumed to be in London (design outside air temperature = -1.9°C) and initially has single glazing. The heating is assumed to be used continuously.

Room heat loss: 167W
 Size of existing radiator: 1600mm L, 700mm H, 103mm D (double panel)
 Existing radiator rated output at MW-AT = 60°C: 234W
 Existing radiator rated output at MW-AT = 50°C: 234W x 0.825 = 193W
 Calculate the Oversize Factor and look up the Temperature Star Rating on the chart.
 Oversize factor: 193/167 = 1.2
 Temperature Star Rating: [no stars] ★★★★★
 Radiator flow temperature: 60°C
 To operate at these temperatures, a specialist heat pump would be required. You must therefore take action to ensure satisfactory operation.

The examples on this page demonstrate the impact of reducing heat losses and increasing radiator output. Use the Guidance Table over the page to redesign the emitter system.

REDUCING FABRIC AND VENTILATION HEAT LOSSES

Reducing the fabric and ventilation heat loss is an efficient way of increasing the Temperature Star Rating because it reduces energy consumption and improves the system efficiency – always consider reducing heat losses when making changes to a house.

Notes and assumptions used to create this guide

- Heat pump likely Seasonal Performance Factor (SPF) is calculated for space heating only in accordance with the following notes and assumptions:
- Loads is used for weather data. (b) Provision of domestic hot water is not included. (c) Room temperature is based on Comfort Winter level 21°C against temperature per BS EN ISO 7730. (d) The heat pump is sized to meet 100% of the space heating load and is the only heat source in the dwelling. (e) GSHP SPF is the SCOP calculated in accordance with EN 14825. (f) GSHP 4/25 COP = 3.1 (NBS minimum threshold). (g) Low temperature in heat emitter guide is at peak design conditions (i.e. at the lowest external design temperature). (h) The temperature difference across the heat emitters is fixed at 1/10th of the emitter circuit flow temperature. (i) Weather compensation is used. (j) HPAW has been added to the electrical consumption of heating and radiator pumps. (k) The heat emitter control system meets current building regulations requirements. (l) Allowance has been made for losses from: piping, buffer vessels, or associated water pumps. (m) The GSHP ground loop is designed with a heat pump only water temperature of 7°C. (n) A ground circulation pump is included. (o) The SPF values for ASHP are 0.7 less than for GSHP, and corrected with 0.4 (p) Installation of covered UPF has floor insulation to BS EN 1256 or building regulations, whichever is the greater, and finishing floor laid over. (q) Installation of A-piled UPF has floor insulation to BS EN 1256 or building regulations, whichever is the greater, and finishing floor laid on top of a proprietary aluminium plate system with air gaps between the aluminium plates, otoboard flooring and finish floor (r) Performance of UPF is calculated according to BS EN 1256 and is shown using differing floor coverings with resistance values of: Carp = 0.02m²/W, (or 15 TDS), Wood = 0.10m²/W, Tile = 0.02m²/W. (s) Required performance of Pan Coils, Pan Convector and Radiators is expressed as an Oversize Factor or heat transfer multiplier to determine the required manufacturer's catalogued output per BS EN 14825 at a mean water to air temperature difference of 60°C. The operators used in the heat transfer equations to calculate the heat transfer multipliers are 1.2 for Standard Radiators, 1.1 for Pan Coils and 1.0 for Pan Convectors. The room temperature used to calculate the heat transfer multipliers is fixed at 21°C.

If the external walls have cavity wall insulation added, windows are replaced with A-rated double glazing, 50% of underfloor insulation is added, and the room is draught-proofed, the example room's Temperature Star Rating is improved:

Improved room heat loss: 976W
 New oversize factor: 193/976 = 2.0
 New Temperature Star Rating: 2 stars ★★
 Radiator flow temperature: 55°C
 Likely GSHP heating SPF: 3.1
 Likely ASHP heating SPF: 2.4

UPGRADING THE EXISTING RADIATORS

Upgrading the existing radiator to one that has a high rated output is another way of increasing the Temperature Star Rating:
 Size of new radiator: 1600mm L, 700mm H, 135mm D (a double convactor with the same frontal area as existing radiator)
 New radiator rated output: 326W
 New oversize factor: 326/167 = 2.0
 New Temperature Star Rating: 2 stars ★★
 Radiator flow temperature: 55°C
 Likely GSHP heating SPF: 3.1
 Likely ASHP heating SPF: 2.4

REDUCING FABRIC AND VENTILATION HEAT LOSSES AND UPGRADING THE EXISTING RADIATORS

The two previous examples can be combined to produce a more efficient installation:
 Improved room heat loss: 976W
 New radiator rated output: 326W
 New oversize factor: 326/976 = 3.4
 New Temperature Star Rating: 4 stars ★★★★★
 Radiator flow temperature: 45°C
 Likely GSHP heating SPF: 3.7
 Likely ASHP heating SPF: 3.0

Reduce the room heat loss by the room floor area to identify the room specific heat loss band on the far left of the table that should be used in the design process.

Use the colour coding (which identifies suitable emitters) and different emitter types, together with Temperature Star Rating, the heating circuit flow temperatures and the likely space heating SPF to select an emitter type and specification that achieves the desired operating conditions.

Is the emitter an underfloor heating system?

If **Yes**, read off the Oversize Factor and multiply it by the room heat loss (in W) to determine the required rated output.

Read off the maximum pipe spacing (PS) to be used in the design.

Use manufacturers' data to select an emitter type able to achieve the required rated output.

Proceed with installation

Panel radiators: Tables are presented as a generic aid to ensure that correct information is being provided within the heat emitter design. Competent heating system designers will be able to provide site-specific solutions to meet your exact demands. Tables cover space heating only - domestic hot water included.

KEY TO GUIDANCE TABLE

REDUCE FABRIC AND VENTILATION HEAT LOSS - System cannot perform at the design parameters stated; consider reducing heat loss and/or load-sharing design with other emitter types.

CONSIDER MEASURES TO REDUCE FABRIC AND VENTILATION HEAT LOSS - System can perform at these design conditions but emitter sizes are likely to be excessive.

CAUTION - System can perform at these design conditions with extra consideration on the emitter and heat pump design.

GO A HEAD - System can perform at the stated efficiencies with the selected emitter design.

Underfloor Pipe Spacing - PS150 means UFH pipes should be spaced at 150mm or less to achieve the design condition.

Oversize Factor - multiply the room heat loss (in W) by the Oversize Factor to determine the required emitter output with a mean water to air temperature difference of 50°C. Oversize Factor is the same as a Heat Transfer Multiplier.

Reducing fabric and/or ventilation heat losses can move a room up to the next specific heat loss band, making it easier to achieve a good SPF.

GUIDANCE TABLE

	Temperature Star Rating	Heating circuit flow temperature °C	Likely space heating SPF		Oversize factors for other emitters					Underfloor heating: screed			Underfloor heating: Aluminium panel		
			GSHP	ASHP	Domestic Fan Convected Radiator	Standard Radiator	Fan Coil Unit	with TILE	with WOOD	with CARPET	with TILE	with WOOD	with CARPET		
Room heat loss less than 30 W/m ²	35	35	4.3	3.6	4.3	6.8	5.0	PS:300	PS:300	PS:200	PS:200	PS:200	PS:150		
	40	40	4.1	3.4	3.1	4.3	3.5	PS:300	PS:300	PS:300	PS:300	PS:200			
	45	45	3.7	3	2.4	3.1	2.6	PS:300	PS:300	PS:300	PS:300	PS:300			
	50	50	3.4	2.7	2.0	2.4	2.1	PS:300	PS:300	PS:300	PS:300	PS:300			
	55	55	3.1	2.4	1.7	1.9	1.7	PS:300	PS:300	PS:300	PS:300	PS:300			
Room specific heat loss 30 to 50 W/m ²	35	35	4.3	3.6	4.3	6.8	5.0	PS:300	PS:200	PS:150	PS:200	Reduce heat loss			
	40	40	4.1	3.4	3.1	4.3	3.5	PS:300	PS:300	PS:300	PS:200	PS:150			
	45	45	3.7	3	2.4	3.1	2.6	PS:300	PS:300	PS:300	PS:200	PS:200			
	50	50	3.4	2.7	2.0	2.4	2.1	PS:300	PS:300	PS:300	PS:200	PS:200			
	55	55	3.1	2.4	1.7	1.9	1.7	PS:300	PS:300	PS:300	PS:300	PS:300			
Room specific heat loss 50 to 80 W/m ²	35	35	4.3	3.6	4.3	6.8	5.0	PS:100	Reduce heat loss		Reduce heat loss				
	40	40	4.1	3.4	3.1	4.3	3.5	PS:200	Reduce heat loss		Reduce heat loss				
	45	45	3.7	3	2.4	3.1	2.6	PS:300	PS:100	PS:100	PS:150				
	50	50	3.4	2.7	2.0	2.4	2.1	PS:300	PS:200	PS:150	PS:200	PS:150			
	55	55	3.1	2.4	1.7	1.9	1.7	PS:300	PS:300	PS:200	PS:200	PS:100			
Room specific heat loss 80 to 100 W/m ²	35	35	4.3	3.6	4.3	6.8	5.0	PS:300	PS:300	PS:300	PS:200	PS:150			
	40	40	4.1	3.4	3.1	4.3	3.5	PS:150	Reduce heat loss		Reduce heat loss				
	45	45	3.7	3	2.4	3.1	2.6	PS:200	Reduce heat loss		Reduce heat loss				
	50	50	3.4	2.7	2.0	2.4	2.1	PS:100	PS:100	PS:150					
	55	55	3.1	2.4	1.7	1.9	1.7	PS:300	PS:200	PS:150	PS:150	PS:100			
Room specific heat loss 100 to 120 W/m ²	35	35	4.3	3.6	4.3	6.8	5.0	PS:300	PS:250	PS:200	PS:150	PS:100			
	40	40	4.1	3.4	3.1	4.3	3.5								
	45	45	3.7	3	2.4	3.1	2.6	Reduce heat loss			Reduce heat loss				
	50	50	3.4	2.7	2.0	2.4	2.1	Reduce heat loss			Reduce heat loss				
	55	55	3.1	2.4	1.7	1.9	1.7								
Room specific heat loss 120 to 150 W/m ²	35	35	4.3	3.6	4.3	6.8	5.0								
	40	40	4.1	3.4	3.1	4.3	3.5								
	45	45	3.7	3	2.4	3.1	2.6	Reduce heat loss			Reduce heat loss				
	50	50	3.4	2.7	2.0	2.4	2.1	Reduce heat loss			Reduce heat loss				
	55	55	3.1	2.4	1.7	1.9	1.7								

Changing the emitter type can enable the emitter to operate at a lower temperature.

Changing the floor covering or UFH can reduce the required emitter temperature.

Changing the emitter specification can reduce the flow temperature and therefore increase SPF.

EXAMPLES of systems designed using the GUIDANCE TABLE

Benefits of reducing fabric and ventilation heat losses

The poorly-insulated example room introduced on the front page has the following heat loss and dimensions:

Original room heat loss: 1677W
 Room size: 4.3m x 2.7m = 11.2m²
 Room specific heat loss: 1677/11.2 = 126 W/m²
 Room specific heat loss band: 120 to 150 W/m²

A higher Temperature Star Rating can be achieved if the room specific heat loss (in W/m²) is reduced. This is indicated in the Design Table by the different colour coding for different specific heat loss bands. Reducing the room heat loss as in the example on the first page, moves the room into a lower room specific heat loss band.

Improved room heat loss: 975W
 Room specific heat loss: 975/11.2 = 74W/m²
 Room specific heat loss band: 50 to 80 W/m²

These examples design standard radiator, fan-assisted radiator and underfloor heat distribution systems that achieve the maximum recommended Temperature Star Rating for this improved room.

Standard radiators

The Oversize Factor required to achieve the maximum recommended Temperature Star Rating is circled on the Guidance Table for a radiator system in a room with a specific heat loss in the 50 to 80 W/m² band.

Room specific heat loss band: 50 to 80 W/m²
 Emitter type: Radiators
 Design Temperature Star Rating: 4 stars
 Design Radiator Flow Temperature: 45°C
 Likely GSHP heating SPF: 3.7
 Likely ASHP heating SPF: 3.0

Required Oversize Factor: 3.1
 Required rated output: 975 x 3.1 = 3024W

Manufacturer: Myson Select SD 70 160 (or equivalent)
 Size: 1600mm L, 700mm H, 135mm D
 Manufacturer's Rating: 3165W

OR
 Manufacturer: Myson Select SX 70 100 (or equivalent)
 Size: 2 No. 1800 mm L, 700mm H, 57mm D
 Manufacturer's Rating: 2 x 1583 = 3166W

Fan-assisted radiators

A fan-assisted radiator will have a higher heat output than a standard radiator the same size. You can therefore achieve a higher Temperature Star Rating without the heat emitter becoming too large for a room with a fixed specific heat loss.

The Oversize Factor required to achieve the maximum recommended Temperature Star Rating is also circled on the Guidance Table for a fan-assisted radiator system.

Room specific heat loss band: 50 to 80 W/m²
 Emitter type: Fan-assisted radiators
 Design Temperature Star Rating: 5 stars
 Design Radiator Flow Temperature: 45°C
 Likely GSHP heating SPF: 4.1
 Likely ASHP heating SPF: 3.4

Required Oversize Factor: 3.1
 Required radiator output: 975 x 3.1 = 3024W
 Manufacturer: Jaga Strada DEE Type 11 (or equivalent)
 Size: 400mm L, 910mm H, 118mm D
 Manufacturer's Rating: 3114W
 OR
 Manufacturer: Jaga Strada DEE Type 11 (or equivalent)
 Size: 2 No. 810 mm L, 650mm H, 118mm D
 Manufacturer's Rating: 2 x 1534 = 3068W

Screed underfloor heating

Depending on the floor construction and covering, an underfloor heat distribution system may be able to run at an even lower heating circuit flow temperature - and therefore higher Temperature Star Rating - in the same room specific heat loss band.

The maximum pipe spacing required to achieve the recommended Temperature Star Rating is circled on the Guidance Table for a screed underfloor heat distribution system with a tile covering.

Room specific heat loss band: 50 to 80 W/m²
 Emitter type: Screed underfloor
 Floor covering: Tile
 Design Temperature Star Rating: 6 stars
 Design Radiator Flow Temperature: 35°C
 Likely GSHP heating SPF: 4.3
 Likely ASHP heating SPF: 3.6
 Maximum underfloor pipe spacing: 100mm

Aluminium panel underfloor heating

An aluminium panel underfloor heat distribution system with a tile covering cannot achieve such a high Temperature Star Rating. The maximum pipe spacing required to achieve the highest recommended Temperature Star Rating is circled on the Guidance Table.

Room specific heat loss band: 50 to 80 W/m²
 Emitter type: Aluminium panel underfloor
 Floor covering: Tile
 Design Temperature Star Rating: 4 stars
 Design Radiator Flow Temperature: 45°C
 Likely GSHP heating SPF: 3.7
 Likely ASHP heating SPF: 3.0
 Maximum underfloor pipe spacing: 150mm

GUIDANCE TABLE

	Temperature Star Rating	Heating circuit flow temperature °C	Likely space heating SPF		Oversize factors for other emitters			Underfloor heating: screed			Underfloor heating: Aluminium panel		
			GSHP	ASHP	Domestic Fan Convectors/Fan-assisted Radiators	Standard Radiator	Fan Coil Unit	with TILE	with WOOD	with CARPET	with TILE	with WOOD	with CARPET
Room heat loss less than 30 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0	PSs 300	PSs 300	PSs 200	PSs 200	PSs 200	PSs 150
	★★★★★	40	4.1	3.4	3.1	4.3	3.5	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 200
	★★★★★	45	3.7	3	2.4	3.1	2.6	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300
	★★★★★	50	3.4	2.7	2.0	2.4	2.1	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300
	★★★★★	55	3.1	2.4	1.7	1.9	1.7	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300
	★★★★★	60	2.8	2.1	1.4	1.6	1.5	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300
Room specific heat loss 30 to 50 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0	PSs 300	PSs 100		PSs 100	Reduce heat loss	
	★★★★★	40	4.1	3.4	3.1	4.3	3.5	PSs 300	PSs 200	PSs 150	PSs 200	PSs 200	PSs 150
	★★★★★	45	3.7	3	2.4	3.1	2.6	PSs 300	PSs 300	PSs 300	PSs 200	PSs 200	PSs 150
	★★★★★	50	3.4	2.7	2.0	2.4	2.1	PSs 300	PSs 300	PSs 300	PSs 300	PSs 200	PSs 200
	★★★★★	55	3.1	2.4	1.7	1.9	1.7	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300
	★★★★★	60	2.8	2.1	1.4	1.6	1.5	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300	PSs 300
Room specific heat loss 50 to 80 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0	PSs 100	Reduce heat loss			Reduce heat loss	
	★★★★★	40	4.1	3.4	3.1	4.3	3.5	PSs 200	Reduce heat loss			Reduce heat loss	
	★★★★★	45	3.7	3	2.4	3.1	2.6	PSs 300	PSs 100	PSs 100	PSs 150		
	★★★★★	50	3.4	2.7	2.0	2.4	2.1	PSs 300	PSs 200	PSs 150	PSs 200	PSs 100	
	★★★★★	55	3.1	2.4	1.7	1.9	1.7	PSs 300	PSs 300	PSs 200	PSs 200	PSs 150	PSs 100
	★★★★★	60	2.8	2.1	1.4	1.6	1.5	PSs 300	PSs 300	PSs 300	PSs 300	PSs 200	PSs 150
Room specific heat loss 80 to 100 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0						
	★★★★★	40	4.1	3.4	3.1	4.3	3.5	PSs 150	Reduce heat loss			Reduce heat loss	
	★★★★★	45	3.7	3	2.4	3.1	2.6	PSs 200			PSs 100	Reduce heat loss	
	★★★★★	50	3.4	2.7	2.0	2.4	2.1	PSs 250	PSs 100	PSs 100	PSs 150		
	★★★★★	55	3.1	2.4	1.7	1.9	1.7	PSs 300	PSs 200	PSs 150	PSs 200	PSs 100	
	★★★★★	60	2.8	2.1	2.1	1.6	1.5	PSs 300	PSs 250	PSs 250	PSs 200	PSs 150	PSs 100
Room specific heat loss 100 to 120 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0						
	★★★★★	40	4.1	3.4	3.1	4.3	3.5						
	★★★★★	45	3.7	3	2.4	3.1	2.6						
	★★★★★	50	3.4	2.7	2.0	2.4	2.1						
	★★★★★	55	3.1	2.4	1.7	1.9	1.7						
	★★★★★	60	2.8	2.1	1.4	1.6	1.5						
Room specific heat loss 120 to 150 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0						
	★★★★★	40	4.1	3.4	3.1	4.3	3.5						
	★★★★★	45	3.7	3	2.4	3.1	2.6						
	★★★★★	50	3.4	2.7	2.0	2.4	2.1						
	★★★★★	55	3.1	2.4	1.7	1.9	1.7						
	★★★★★	60	2.8	2.1	1.4	1.6	1.5						
Room specific heat loss less than 120 to 150 W/m²	★★★★★	35	4.3	3.6	4.3	6.8	5.0						
	★★★★★	40	4.1	3.4	3.1	4.3	3.5						
	★★★★★	45	3.7	3	2.4	3.1	2.6						
	★★★★★	50	3.4	2.7	2.0	2.4	2.1						
	★★★★★	55	3.1	2.4	1.7	1.9	1.7						
	★★★★★	60	2.8	2.1	1.4	1.6	1.5						

R S D S D F

Designing ground heat exchangers is a complex engineering problem..... the installer shall adopt a conservative approach.....

≥30kW or incorporate ground loop replenishment through cooling or otherwise, the installer should undertake the design process making use of specialist recognised design tools and/or seek advice from an expert.

Software.... validated for UK use..... following parameters are used

- a) Site average ground temperatures (or annual average air temperatures).
- b) Site ground thermal conductivity values (in W/mK), including...water table depth
- c) Accurate assessment of yearly CH energy consumption (kWh)
- d) Accurate assessment-max ground power extracted (kW) (i.e. HP evap capacity)
- e) Accurate assessment-temp of the thermal transfer fluid entering the heat pump.

The temp of the thermal transfer fluid entering the heat pump shall be designed to be >0 °C at all times for 20 years.

Simplified design methods, (including look-up tables and nomograms)..... validated for UK ground conditions and installation practices.....

If proprietary software is not being used, systems ≤ 30 kW without ground loop replenishment..... shall use the following procedure to designing ground HX:

Total yearly CH energy consumption (kWh) shall be estimated including

- internal heat gains,
- solar insolation heat gains
- local external air temperature
- Building heating pattern used (e.g. continuous, bi-modal, Economy10 etc.)

Table 3

Estimated total heating energy consumption per a year for space heating and domestic hot water

kWh [1]

Heat pump heating capacity at 0°C ground return temperature and design emitter temperature, H

kW [2]

FLEQ run hours
[1]/[2]

$$\text{FLEQ run hours} = \frac{\text{Total heating energy consumption}}{\text{Heat pump capacity}}$$

Estimated average ground temperature

°C [4]

App B for
Annual mean air temp

Estimated ground thermal conductivity

W/mK [5]


BGS – borehole &
horizontal surveys
GSHPA VBS for TRT
App C for rock types

Maximum power to be extracted per unit length borehole, horizontal or slinky ground heat exchanger (from the charts and look-up tables),

W/m [6]

Region	Mean monthly and annual air temperature /°C (1981-2010)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
Scotland (Dyce)	3.5	3.8	5.3	7.2	9.6	12.4	14.6	14.4	12.2	9.1	5.9	3.6	8.5
Scotland (Stornoway)	4.8	4.7	5.6	7.1	9.3	11.5	13.4	13.5	11.8	9.3	6.8	5.1	8.6
Scotland (Leuchars)	3.6	4.0	5.7	7.5	10.0	12.9	15.0	14.8	12.7	9.5	6.1	3.6	8.8
Islands (Boulmer)	4.4	4.5	5.9	7.4	9.8	12.6	14.7	14.8	12.9	10.1	6.9	4.6	9.0
Scotland (Abbotsinch)	4.0	4.2	5.9	8.0	10.9	13.5	15.4	15.0	12.6	9.4	6.2	3.8	9.1
Ireland (Aldergrove)	4.4	4.5	6.2	8.1	10.9	13.5	15.4	15.0	13.0	9.9	6.8	4.7	9.4
North-eastern (Leeming)	3.8	4.1	6.1	8.1	11.0	13.9	16.2	15.9	13.5	10.0	6.5	3.9	9.4
North-western (Carlisle)	4.3	4.5	6.2	8.2	11.1	13.7	15.7	15.4	13.2	10.1	6.8	4.2	9.4
Islands (Elmdon)	4.1	4.1	6.4	8.4	11.5	14.5	16.8	16.5	13.9	10.3	6.7	4.2	9.8
Islands (Aberporth)	5.3	5.1	6.6	8.2	10.9	13.4	15.2	15.3	13.7	11.0	8.0	5.9	9.9
Pennines (Finningley)	4.2	4.4	6.6	8.6	11.7	14.6	16.9	16.8	14.2	10.6	6.9	4.4	10.0
Pennines (Ringway)	4.5	4.6	6.6	8.7	11.9	14.5	16.6	16.3	14.0	10.6	7.1	4.6	10.0
East Anglia (Honington)	4.1	4.1	6.5	8.6	11.9	14.8	17.3	17.2	14.6	11.0	7.0	4.4	10.1
South-eastern (Gatwick)	4.3	4.4	6.7	8.7	12.0	14.9	17.3	17.0	14.3	10.9	7.1	4.6	10.2
South-eastern (Hurn)	4.9	4.9	6.8	8.7	12.1	14.8	17.0	16.8	14.4	11.2	7.6	5.2	10.4
South-eastern Valley (Filton)	5.0	5.0	7.2	9.2	12.4	15.3	17.3	17.1	14.7	11.3	7.8	5.3	10.6
South-western (Plymouth)	6.4	6.2	7.7	9.3	12.2	14.6	16.6	16.7	14.8	12.1	9.0	7.0	11.0
South-western Valley (Heathrow)	5.2	5.2	7.6	9.9	13.3	16.4	18.7	18.4	15.6	12.0	8.0	5.5	11.3

	Type of rock	Thermal conductivity (/W/mK)			
		Min	Max	Recommended	
Consolidated rock	Sand, dry	0.3	0.8	0.4	
	Gravel, dry	0.4	0.5	0.4	
	Peat, soft lignite	0.2	0.7	0.4	
	Clay/silt, dry	0.4	1.0	0.5	
	Clay/silt, water saturated	0.9	2.3	1.7	
	Gravel, water saturated	1.6	2.0	1.8	
	Claystone, siltstone	1.1	3.5	2.2	
	Sand, water saturated	1.5	4.0	2.4	
	Hard coal	0.3	0.6	0.4	
	Gypsum	1.3	2.8	1.6	
Sediments	Marl	1.5	3.5	2.1	
	Sandstone	1.3	5.1	2.3	
	Conglomerates	1.3	5.1	2.3	
	Limestone	2.5	4.0	2.8	
	Dolomite	2.8	4.3	3.2	
	Anhydrite	1.5	7.7	4.1	
	Salt	5.3	6.4	5.4	
	Tuff	1.1	1.1	1.1	
	Vulcanite, alkaline to ultra-alkaline	e.g. andesite, basalt	1.3	2.3	1.7
	Plutonite, alkaline to ultra-alkaline	Gabbro	1.7	2.5	1.9
	Diorite	2.0	2.9	2.6	
Igneous rocks	Vulcanite, acid to intermediate	e.g. latite, dacite	2.0	2.9	2.6
		e.g. rhyolite, trachyte	3.1	3.4	3.3
	Plutonite, acid to intermediate	Syenite	1.7	3.5	2.6
		Granite	2.1	4.1	3.4
	Slightly metamorphic	Clay shale	1.5	2.6	2.1
		Chert	4.5	5.0	4.5
Metamorphic rock	Mica schist	1.5	3.1	2.2	
	Gneiss	1.5	3.1	2.2	
	Moderately to highly metamorphic	Marble	1.3	3.1	2.5
	Vulcanite, acid to intermediate	Amphibolite	1.9	4.0	2.9
		e.g. rhyolite, trachyte	2.1	3.6	2.9
		Quartzite	5.0	6.0	5.5






Maximum power to be extracted per unit length of borehole heat exchanger (W/m) with 1800 FLEQ run hours

Conditions for use: Heat extraction only (inc. hot water)

6m minimum borehole spacing. Only valid for boreholes arranged in a line; not applicable for a large number of systems in a small area.
 Table created assuming: 130mm borehole diameter; single U-tube; 32mm OD SDR-11, PE100 pipe with thermal conductivity = 0.420W/m/K; 52mm pipe centre-pipe centre to centre spacing; 25% Mono Ethylene Glycol thermal transfer fluid; Re > 2500 in the borehole active elements; thermally enhanced grout with thermal conductivity = 2.4W/m/K. Assumptions result in borehole thermal resistance = 0.1 m.K/W at 12°C mean ground temp. and 2.5W/m/K average ground thermal conductivity.



Maximum power to be extracted per unit length of horizontal ground heat exchanger (W/m) with 1800 FLEQ run hours

Conditions for use:
 Heat extraction only (inc. hot water)
 0.75m minimum pipe spacing ($d > 0.7$)
 Pipe depth between 0.8m and 1.0m
 Table created assuming 25mm OD SDR 11

Table created assuming a relationship between the mean monthly temperature swing and annual mean ground temperature




Table 3

Estimated total heating energy consumption per a year for space heating and domestic hot water

kWh [1]

Heat pump heating capacity at 0°C ground return temperature and design emitter temperature, H

kW [2]

FLEQ run hours
[1]/[2]

$$\text{FLEQ run hours} = \frac{\text{Total heating energy consumption}}{\text{Heat pump capacity}}$$

Estimated average ground temperature

°C [4]

App B for
Annual mean air temp

Estimated ground thermal conductivity

W/mK [5]

BGS – borehole &
horizontal surveys
GSHPA VBS for TRT
App C for rock types

Maximum power to be extracted per unit length borehole, horizontal or slinky ground heat exchanger (from the charts and look-up tables),

W/m [6]

Assumed heat pump SPF (from heat emitter guide)

[7]

Maximum power extracted from the ground (i.e. the heat pump evaporator capacity)

W

[8]

$$G = [2] * 1000 * (1 - 1/[7])$$

$$H \left(1 - \frac{1}{SPF} \right)$$

Length of ground heat exchanger calculated using the look-up tables

m

[9]

$$L_b = \frac{G}{g}$$

$$L_b = [8]/[6]$$

Borehole, horizontal loop or slinky spacing, d

m

[10]

$$A = L_b d$$

Total length of ground heat exchanger active elements, $L_p = [9] * R_{pt}$

m

[11]

$$L_p = L_b R_{pt}$$

$R_{pt} = 2$ – boreholes,
1 - horizontal & min pipe length to trench length slinky

Total length of ground heat exchanger active elements installed in the ground, L_p'


m

[12]

Shall ensure.... turbulent flow.... Reynolds number.... should be ≥ 2500

Geological situation on drilling or digging show substantial deviation.... design ground HX.... recalculated

Hydraulic layout of the ground loop... pumping power... $< 2.5\%$ HP capacity



HP always following manufacturer's instructions

ASHP - Avoid air recirculation.....

.....

ASHP Permitted Development rights (England and Wales) MCS 020 – comply with
Planning Standards.

Closed-loop ground heat exchangers

The following commissioning procedure shall.....

Ground arrays (including header pipes and manifolds)....

flushed as one system to remove all debris and purged to remove all air.....

shall flush vertical and horizontal ground arrays in both directions....

should flush slinky ground arrays in both directions.....

HP (and its pipework) shall be isolated from ground HX during this process....

HP (and its pipework) shall be flushed & purged as another system, in isolation....

Once the ground array is free from debris and visible air bubbles/pockets, purging should continue on the entire system.... at least 15 minutes with a minimum flow velocity of 0.6m/s.... see Table 4

Pipe outer diameter mm	Recommended flow rate for flushing and initial purging		Minimum flow rate for purging micro air bubbles after flushing and initial
	Horizontal ground arrays (1m/s) /litres/min	Slinky ground arrays (1.5m/s) /litres/min	All ground arrays (0.6m/s) /litres/min
5	20	30	12
2	32	48	20
0	50	76	31
0	79	118	48
5	133	200	81

Table 4: Flow rates required for different pipe diameters to achieve 0.6m/s flow velocity for purging micro air bubbles; 1m/s for flushing and purging horizontal ground arrays of debris and visible air bubbles; and 1.5m/s for slinky ground arrays. Parallel loops or layouts with variable pipe geometry may require higher flow rates to achieve these flow speeds.

Once purged.... shall.... pressure test.... entire ground source HX to BS EN 805 section 11.3.3.4

Antifreeze.... freeze protection down to -10 °C

Antifreeze quantity and type.... appropriate for the system design.... flow rate.... viscosity.... choice of ground array circulation pump.

Quantity of biocide recommended by the antifreeze manufacturer/supplier... added 2 separate, random samples.... refractometer tested.... confirm -10 °C....

Evidence should be provided to the customer that this has been achieved.

The Ground Source Heat Pump Association “Closed-loop vertical borehole design, installation and materials standard” (VBS) further commissioning guidance



a comprehensive documentation pack.... Including....

- Sizing
- Domestic hot water services
- Emitter design
- Ground heat exchanger design
- System performance

Item	Included	Not included	Comments
Sizing			
Details of the heat loss calculations made on the building, including the value of the heat loss coefficient determined for the building, the design internal and external air temperatures and average external air temperature used for heat loss through the floor.	<input type="checkbox"/>	<input type="checkbox"/>	
The heat pump power output at the design ambient temperature and design emitter temperature.	<input type="checkbox"/>	<input type="checkbox"/>	
For air-source systems, evidence that the energy requirements of the heat pump's defrost cycles can be met inside the design temperature range.	<input type="checkbox"/>	<input type="checkbox"/>	
For installations where other heat sources are available to the same building, what proportion of the building's space heating and domestic hot water has been designed to be provided by the heat pump.	<input type="checkbox"/>	<input type="checkbox"/>	
Domestic hot water services			
Evidence for the choice of domestic hot water cylinder.	<input type="checkbox"/>	<input type="checkbox"/>	
Emitter design			
The heat pump power output at the design ambient temperature and design emitter temperature.	<input type="checkbox"/>	<input type="checkbox"/>	
All specific room heat losses (in W/m ²);	<input type="checkbox"/>	<input type="checkbox"/>	

A well **designed, installed, commissioned and maintained** GSHP system is:

- Cheaper than Gas, Oil, Wood, Coal or Economy 7
- Has no Carbon Monoxide or flueing issues
- Easily achieves a 10% or much more RE target
- Can heat and cool the building
- Compatible with Domestic Solar Hot Water

